



City of Columbus
Mayor Michael B. Coleman

Department of Public Utilities
Tatyana Arsh, P.E. Director

DATE: August 18, 2008

TO: Joel S. Taylor
Director, Department of Finance and Management

FM: Tanya Arsh, P.E.
Director of Public Utilities

RE: Bid Recommendation - #SA002973
Replacement Pumps & Motors for Blacklick Booster Station

The low bid from APO Pumps and Compressor did not meet specifications. They submitted on a 6" x 5" pump and our installation requires an 8" x 6" pump.

The second lowest bid from Motion Industries was determined by the Purchasing Office to be non-responsive.

The third lowest bid from McLaughlin & Associates Co., Inc. did not meet the specifications because they also submitted on a 6" x 5" pump. They did not specify the products they intended to supply in the bid document and did not respond to several requests to do so.

The fourth lowest bid from Applied Industrial Technologies, Inc. met all of our specifications. I recommend the bid be awarded to Applied Industrial Technologies, Inc., 3855 Business Park Drive, Columbus, Ohio 43204 as the lowest, responsive, responsible and best bid to meet specifications for the Replacement Pumps and Motors for Blacklick Booster Station.

There were a total of ten bids from eight different vendors.

If additional information is needed please contact Greg Moore at 645-3726.

pc: Rick Westerfield
Craig Charleston
Danella Pettenski
Dwayne Maynard
James Bond

Utilities Complex	910 Dublin Road	Columbus, Ohio 43215
Director's Office	614/645-6141	FAX: 614/645-8019 TDD: 614/645-6454
Power and Water Division	614/645-7020	FAX: 614/645-8177 TDD: 614/645-7188
Operational Support Division	614/645-1508	
Fairwood Complex	1250 Fairwood Avenue	Columbus, Ohio 43206
Sewerage and Drainage Division	614/645-7175	FAX: 614/645-3801 TDD: 614/645-6338

**CITY OF COLUMBUS, OHIO
DEPARTMENT OF PUBLIC UTILITIES
DIVISION OF POWER & WATER/WATER**

**BID TABULATION – SA002973 - OPENED JULY 24, 2008
REPLACEMENT 6" PUMPS & MOTORS**

<u>COMPANY & EQUIPMENT</u>	<u>EXTENDED PRICE</u>	
APO PUMPS & COMPRESSORS		
PUMPS – PACO 5X6 KP SERIES	\$18,294.00	
MOTORS – BALDOR ECP84406T-4	<u>\$27,576.00</u>	
(EXCEPTIONS NOTED)	\$45,870.00	TOTAL
MOTION INDUSTRIES		
PUMPS – NOT STATED	\$18,960.00	
MOTORS – NOT STATED	<u>\$28,995.29</u>	
	\$47,955.29	TOTAL
MCLAUGHLIN & ASSOC. CO., INC.		
PUMPS – AURORA 411 5X6X17	\$27,840.00	
MOTORS – BALDOR ECP84406T-4	<u>\$27,510.00</u>	
	\$55,350.00	TOTAL(ALTERNATE)
APPLIED INDUSTRIAL TECHNOLOGIES, INC.		
PUMPS – AMERICAN MARSH HD 6X8-18	\$34,749.00	
MOTORS – BALDOR ECP84406T-4	<u>\$25,476.54</u>	
	\$60,225.54	TOTAL
STEFFENS - SHULTZ, INC.		
PUMPS – BELL & GOSSETT VSX 6X8X17/2A	\$35,190.00	
MOTORS – BALDOR ECP84406T-4	<u>\$30,450.00</u>	
	\$65,640.00	TOTAL
SABATKA, DAVIS & ASSOCIATES, INC.		
PUMPS – PATTERSON 8X6 MI-C	\$49,770.00	
MOTORS – BALDOR CP4406T-4	<u>\$19,602.00</u>	
	\$69,372.00	TOTAL(ALTERNATE)
SABATKA, DAVIS & ASSOCIATES, INC.		
PUMPS – PATTERSON 8X6 MI-C	\$49,770.00	
MOTORS – BALDOR ECP84406T-4	<u>\$23,634.00</u>	
	\$73,404.00	TOTAL
MCLAUGHLIN & ASSOC. CO., INC.		
PUMPS – AURORA 411 6X8X20	\$47,664.00	
MOTORS – BALDOR ECP84406T-4	<u>\$27,510.00</u>	
	\$75,174.00	TOTAL
D & F DISTRIBUTORS, INC.		
PUMPS – AURORA 411BF 6X8X18A	\$59,700.00	
MOTORS – BALDOR ECP84406T-4	<u>\$25,200.00</u>	
	\$84,900.00	TOTAL
PROCESS PUMP & SEAL, INC.		
PUMPS – AMERICAN MARSH 340/6X8-18 HD	\$59,965.50	
MOTORS – BALDOR ECP84406T-4	<u>\$29,568.00</u>	
	\$89,533.50	TOTAL

