


- 1 CUSTOMER TO INSTALL PRIVATE RISER ON STAND OFFS AND WEATHER HEAD PER SPECS GIVEN
- 2 CUSTOMER TO INSTALL PRIVATE 4/0 UNDERGROUND CABLE PER CUSTOMERS PLANS
- 3 CUSTOMER TO INSTALL FREE STANDING METER TRIM PER SPECS GIVEN

AEP FUTURE CONTACTS.
 ENGINEER- RICHARD KERNS, 614-853-4103- CONDUITS
 EXPEDITOR- BARB SIMS, 614-853-4108 - ELECTRICAL
 INSPECTIONS (HAVE ORDER NUMBER WHEN CALLING IN)
 SCHEDULER- MARK EMMONS 614-853-4102

 An AEP Company	CUSTOMER CONTACT MARC GAWELL 740-808-4352	CIRCUIT WILSON F002014 OWR - 71923736	VOLTAGE 7620KV, 120/240V	PRINT NO.	DESIGNED R. KERNS	DATE 4/3/19	3321 WICKLOW RD RP 4 POLES, INSTALL SPANS OF #2 1PH, 37.5KVA/B AND RP OPEN WIRE SEC.	
	DN -	TWP	COUNTY FRANKLIN	APPROVED DATE	DRAWN R. KERNS	DATE 4/11/19		
	RN -	COUNTY FRANKLIN	MAP COLUMBUS	QUAD. SW	WORK ORDER NO. DOP0305652			
	EQUIP. PRE ORDER	TRUCK ACCESS YES	SHEET 1	TOTAL 1	REV'N X	OH X		UG X