

ORD# 2084-2006

**Information to be included in all Legislation authorizing entering into Contracts:**

**The names of all companies bidding or submitting an RFP or RFSQ.**

Delta Star, Inc.  
GE Prolec/ Pepco  
Niagara Transformer Corp.

**The location by City and State of all companies bidding or submitting an RFP or RFSQ.**

Delta Star, Inc., Lynchburg, Va.  
GE Prolec/ Pepco, Uniontown, Oh  
Niagara Transformer Corp., Buffalo, NY

**The status, Majority, MBE or FBE, of all companies bidding or submitting an RFP or RFSQ.**

Delta Star, Inc. - Majority-owned businesses  
GE Prolec/ Pepco - Majority-owned businesses  
Niagara Transformer Corp. – MBE ( Veteran Small Business)

**A full description of all work to be performed including a full description of work to be performed during any known phasing of the contract.**

Transformer T-0 is located at 555 Dublin Ave (Nationwide Blvd) in the Dublin Avenue Substation and it is one of three (3) distribution transformers feeding downtown customers as well as the Dublin Road Water Treatment Plant. At this time the Division has switched load to the other two transformers, but there is no back up for these two transformers. It is critical to have the replacement for transformer T-0 in place before the summer load and power peak. If there is an outage of the T-1 or T-3 transformers, a power outage could affect the Dublin Road Water Treatment Plant, City Hall, the Police Station, and other downtown Columbus customers.

The manufacturer will design the transformer to meet the specifications and fit on the existing pad. The manufacturer will purchase the material and fabricate the transformer. The manufacturer is responsible for the transportation and erecting pad at the Dublin Avenue Substation.

**A narrative timeline for the contract including a beginning date, beginning and ending dates for known phases of the contract and a projected ending date.**

Informal bid opening 11-6-06

Passes City Council on 12-4-06  
Contracts signed approximately 12-18-06  
Shop Drawing preparation approximately 8 weeks  
On board shop drawing approval approximately 2-19-07  
Transformer manufacturing approximately 14 weeks  
Transformer witness testing approximately 4-18-07  
Ship from factory to Dublin Ave Substation approximately 4 weeks 5-18-07

**An estimate of the full estimated cost of the Contract including a separate estimate of any and all phases or proposed future contract modifications.**

\$ 1,351,050.03