

**2509.11 Electric Fire Pump installation.**

Whenever a building includes the installation of an electric motor-driven fire pump, at least one Emergency Power Supply (EPS) with an energy source as outlined in Section 5.1.1 of NFPA 110, “Standard for Emergency and Standby Power Systems” or a successor Standard, shall be provided.