

OSHA CITATIONS

ISSUE DATE	LOCATION	PROPOSED TYPE	VIOLATION	PROPOSED PENALTY	FINAL TYPE	FINAL PENALTY
1/30/2003	Kokosing Const. Co., Inc. Martin Luther King Bridge Project #13190	Serious	Citation 1, Item 1: The general contractor and controlling employer did not insure fall protection systems were in compliance with the regulations in that L&M Lignos employees were working on a 2-section mobile scaffold that was approx. 10'6" high, chipping and removing decaying cement from under the two most easterly arches of the bridge. Employees fastened their lanyards to the top guardrail of the scaffold on or before January 30, 2003.	\$4,000.00	Vacated	Zero
4/30/2003	Kokosing Const. Co., Inc. US 33 Lancaster Bypass Project #13246	Serious	Citation 1, Item 1: On the 33 bypass where trenching work was performed, the GFCI attached from the truck to the Milwaukee Impact wrench was not opening.	\$1,125.00	Paid	\$1,125.00
10/29/2003	Kokosing Const. Co., Inc. SR 79 Hebron/Heath Project #13270	Other	Citation 1, Item 1: At the worksite the employer did not insure that the spoil pile was located at least 2 feet away from the edge of the trench thereby exposing employees to a caught-in/stuck-by hazard. On or about 9/15/03, an employee was fatally injured in a trench collapse	\$2,500	Paid	\$2,500
		Other	Citation 1, Item 2: At the worksite the employer did not insure that daily inspections of the excavation, the adjacent areas and protective systems were conducted by a competent person for evidence of a situation that could have resulted in possible cave-ins, indications of failure of protective systems, hazardous atmospheres, or	\$2,500	Vacated	\$0

