

Information to be included in all Legislation authorizing entering into a Contract:

1. **The names, contract compliance no. & expiration date, location by City/State and status of all companies (NPO, MAJ, MBE, FBE, HL1, AS1, or MBR) submitting a competitive bid or submitting an RFP or RFSQ.**

Name	C.C. No./Exp. Date	City/State	Status
Conie Construction Co.	31-0800904 – 11/16/12	Columbus, Oh	MAJ
Danbert, Inc.	31-1029004 – 8/16/12	Plain City, Oh	MAJ
Bale Contracting, Inc.	31-0996994 – 4/19/12	Columbus, Oh	F1

2. **What type of bidding process was used (ITB, RFP, RFSQ, Competitive Bid).**

Bids were formally advertised on the City's Vendor Services website with a bid opening date September 14, 2011.

3. **List the ranking and order of all bidders.**

1. Conie Construction Co.	\$1,831,720.00
2. Danbert, Inc.	\$1,880,527.00
3. Bale Contracting, Inc.	\$1,915,298.00

4. **Complete address, contact name and phone number for the successful bidder only.**

Conie Construction Co.
1340 Windsor Ave.
Columbus, Ohio 43211
Craig Conie, President (614) 291-5931

5. **A full description of all work to be performed including a full description of work to be performed during any known phasing of the contract.**

Providing the necessary labor, material, and equipment to replace main line water valves and appurtenances at various locations within the Columbus Water Distribution system, and such other work as may be necessary to complete the contract in accordance with the plans and specifications.

6. **A narrative timeline for the contract including a beginning date, beginning and ending dates for known phases of the contract and a projected ending date.**

Beginning date = December 2011
End date = 720 calendar days after NTP

7. **A narrative discussing the economic impact or economic advantages of the project; community outreach or input in the development of the project; and any environmental factors or advantages of the project.**

This project is needed to replace broken valves in the distribution system. These valves are typically found broken in the closed position. These replacements will improve fire flows and water quality throughout the system by eliminating these artificial dead-ends. The replaced valves will also allow for quicker emergency responses and minimize the size of shut-offs needed for system maintenance.

8. **An estimate of the full cost of the Contract including a separate estimate of any and all phases or proposed future contract modifications.**

\$1,831,720.00 – construction contract with Conie Construction Co.