

SERVICE STATEMENT
AN22-008
71.6 +/- acres in Madison Township
HARRIET SB LEVIN

The following statements were included in the Council approved service ordinance for this annexation.

71.6+/- acres in Madison Township upon the annexation of said area to the city of Columbus:

Public Safety: The city of Columbus, Department of Public Safety will be able to provide the appropriate level of safety related services to the proposed annexation area. Such services will include police and fire protection as well as emergency medical service to the subject property.

While the petitioner for annexation may have proposed future development plans for the property in question, the Department of Public Safety requests that the City exercise its discretion in the coming development planning and review process to ensure any future development will be properly served by the Department of Public Safety. Discussions between the City and the present property owner or any future developers regarding post annexation changes in zoning or other changes to the property should include the Department of Public Safety and the Department of Development to ensure any proposed development of the annexation property may be adequately accommodated. Specific details for safety services are dependent upon the parameters of future development that is ultimately approved by the City.

Sanitation: The station has no objection to this request.

Transportation: Maintenance will be available for any additional right-of-way that may be included in this annexation request. If this annexation contains existing signalized intersections, those intersections and signals are subject to Transportation Division Policy, which appeared in the December 6, 2003 Columbus City Bulletin, and any subsequent updates thereto.

Water: This site will be served by an existing 16-inch water main located in Winchester Pike Road or a 16" water main in Brice Road, the connection to which will be made at the owner's expense.

Sewers: All sanitary and storm sewers required shall be constructed privately by the owners and developers at their own cost and expense with no cost to the City.

Sanitary: This site is tributary to the 36" sanitary sewer, RP-10094, which will need to be extended from approximately 1,350 feet north of the parcel. The owner will be responsible for obtaining easements to extend this sanitary sewer to the site. The sewer must be extended across the site to the adjacent properties on the north side of Winchester Pike. Mainline extension design and construction costs shall be the responsibility of the property owner and/or developer.

Storm: All storm sewers necessary for development/redevelopment of the area shall be designed in accordance with design policy and applicable codes in effect at the time of development.