



# City of Columbus

Office of City Clerk  
90 West Broad Street  
Columbus OH 43215-9015  
columbuscitycouncil.org

## Legislation Text

**File #:** 1011-2005, **Version:** 1

**BACKGROUND:** The original contract for the Dublin Road Water Plant Low Service Spare Pump Bowl Reconditioning project provided for construction services to furnish all materials; equipment and labor necessary to recondition the low service spare pump bowl, and such other work as may be necessary. Upon commencing the Spare Pump Bowl Reconditioning project the contractor Moody's of Dayton determined the pump impeller shaft was worn in the bearing areas and the housing for the bearing was broken; as these items could not be pre-determined prior to disassembling the pump, a contract modification is necessary to perform this additional unanticipated work. This modification provides for additional Construction services that could not be initially foreseen due to field conditions encountered during construction.

**EMERGENCY PROVISION:** Emergency legislation is being requested to provide these services concurrently with the ongoing construction contract.

**CC 329.16 CONTRACT MODIFICATIONS:**

1. Amount of additional funds to be expended under this modification: \$7,986.00.
2. The extent of additional services could not be initially foreseen due to field conditions encountered during construction.
3. The work under this contract modification is a continuation of work previously performed by the Contractor, therefore, no other processes were used for procurement of these services.
4. The cost of this modification is based on material and labor, and was negotiated between the Consultant and the City, as documented by the Consultant's quotation letter, and verified by the Project Engineer.

**CONTRACT AMOUNT:**

Original contract amount	\$ 60,455.00
Modification No.1	\$ 7,986.00
New contract amount	\$ 68,441.00

**FISCAL IMPACT:** The last authorization for expenditures for construction on this project occurred November 29, 2004 for the original contract in the amount of \$60,455.00. \$130,000 was budgeted for this project.

**CONTRACT COMPLIANCE NUMBER:** 31-0641203

To authorize the Director of Public Utilities to modify the contract with Moody's of Dayton, Inc., for the Dublin Road Water Plant Low Service Spare Pump Bowl Reconditioning project, for the Division of Water, and to authorize the expenditure of \$7,986.00 from the Water System Operating Fund, and to declare an emergency. (\$7,986.00)

WHEREAS: Contract No. EL005081 was authorized by Ordinance No. 2095-2004, passed November 11, 2004, was executed January 25, 2005 and approved by the City Attorney on February 7, 2005, and

WHEREAS: Upon commencing the Spare Pump Bowl Reconditioning project the contractor Moody's of Dayton determined the pump impeller shaft was worn in the bearing areas and the housing for the bearing was broken, and

WHEREAS: These items could not be pre-determined prior to disassembling the pump, a contract modification is necessary to perform this additional unanticipated work, and

WHEREAS: It is necessary to modify Contract No. EL005081 to provide for Dublin Road Water Plant Low Service Spare Pump Bowl Reconditioning Modifications, and

WHEREAS: This modification provides for an increase of \$7,986.00 to this contract, and

WHEREAS: An emergency exists in the usual daily operation of the Division of Water, Department of Public Utilities, in that it is immediately necessary to authorize the Director of Public Utilities to modify Contract No. EL005081, for Dublin Road Water Plant Low Service Spare Pump Bowl Reconditioning project, and it is necessary to provide these construction services concurrently with the ongoing construction contract, therefore emergency legislation is being requested, for the preservation of public health, peace, property and safety now, therefore,

BE IT ORDAINED BY THE COUNCIL OF THE CITY OF COLUMBUS

Section 1. The Director of Public Utilities be and is hereby authorized to modify Contract No. EL005081 with Moody's of Dayton, Inc. in the amount of \$7,986.00, for Dublin Road Water Plant Low Service Spare Pump Bowl Reconditioning project, for the Division of Water, Department of Public Utilities, Contract No. 1068, terms and conditions of which are on file in the office of the Division of Water.

Section 2. That for the purpose of paying the cost thereof, the expenditure of \$7,986.00 is hereby authorized from the Water System Operating Fund, Department of Public Utilities, Division of Water, Dept./Division No. 60-09, Object Level Three 3372, OCA Code 602425.

Section 3. That for the reasons stated in the preamble hereto, which is hereby made a part hereof, this ordinance is hereby declared to be an emergency measure and shall take effect and be in force from and after its passage and approval by the Mayor, or ten days after passage if the Mayor neither approves nor vetoes the same.